

GENERAL NOTES

1. FIELD VERIFY ALL EXISTING CONDITIONS AND THEIR COMPATIBILITY WITH NEW CONSTRUCTION PRIOR TO THE COMMENCEMENT OF WORK. COORDINATE DISCREPANCIES WITH ARCHITECT.
2. DO NOT SCALE DRAWINGS.
3. SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR MORE INFORMATION.
4. DASHED LINES REPRESENT WALLS AND DOORS TO BE REMOVED.
5. ALL DIMENSIONS ARE TO FACE OF WALL, UNLESS NOTED OTHERWISE.
6. CONTRACTOR SHALL PROTECT ALL EXISTING FINISHES FROM DAMAGE DURING DEMOLITION AND REPAIR OR REPLACE ANY MATERIAL THAT IS DAMAGED.
7. CONTRACTOR SHALL VERIFY LOCATION OF ALL DUCTWORK, WATERLINES, GAS LINES & OTHER UTILITIES SERVING THE EXISTING BUILDING & KEEP THEM IN WORKING ORDER.
8. COVER RETURN AIR OPENINGS BEFORE AND DURING CONSTRUCTION.
9. PREPARE ALL WALLS AFFECTED BY DEMOLITION TO RECEIVE NEW FINISHES.

DEMOLITION FLOOR PLAN KEYNOTES

QP-01	SAVE AND REUSE DOOR & FRAME (SEE DOOR SCHEDULE FOR PLACEMENT)
QP-02	ALTERNATE #1: DEMOLISH C.M.U. WALL AS REQ'D TO ACCOMMODATE NEW WINDOW. CORD. OPENING SIZE W/ STOREFRONT MULLION SPACING. RE: AEO1
QP-03	REMOVE AND SALVAGE EXISTING CARPET, PREP FLOOR AS REQUIRED TO RECEIVE NEW FINISH.
QP-04	EXISTING ELECTRICAL PANEL TO REMAIN
QP-05	REMOVE AND DISCARD INTERIOR DOORS, HARDWARE, AND FRAMES - WILL BE PICKED UP BY SUU LOCKSHOP
QP-06	REMOVE AND DISCARD EXISTING CEILING ABOVE, DISCARD ALL LIGHTING
QP-07	REMOVE METER & CAP LINES
QP-08	C.M.U. WALL
QP-09	PREPARE CEILING AND WALL AS NEEDED TO TERMINATE NEW COMMUNICATION CONDUITS IN THIS AREA.
QP-10	SAWCUT BLOCK TO ENLARGE OPENING FOR NEW 3'-0" DOOR

CLIENT

**SOUTHERN
UTAH
UNIVERSITY**
DIGITAL PHOTO LAB
UNIVERSITY BUILDING # 132
STATE BUILDING # 4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER


ARCHIIPLEX
GROUP

architecture • planning • design services

1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

PROFESSIONAL SEAL



ISSUE

MARK	DATE	DESCRIPTION
------	------	-------------


DFCM CONTRACT NO:	077004
DFCM PROJECT NO:	06126730
ARCHIPLEX PROJECT NO:	0620.01
DRAWN BY:	E. RUSTEN
CHECKED BY:	R. STANISLAW
SCALE:	1/4"=1'-0"
DATE:	OCTOBER 27, 2006

KEY PLAN

SHEET TITLE

DEMOLITION PLAN

AD101



A1 | DEMOLITION FLOOR PLAN


AD101

REF.


SCALE: $1/4" = 1'-0"$

4' 3' 2' 1' 0' 2' 4' 8'

PLAN



SCALE: 1/4" = 1'-0"



ROOM # — 131
TYPE — 3D
ELEVATION — 101
A.F.F.

CP-01	JOIN EXISTING TO NEW LAY-IN CEILING SYSTEM NEAR DASHED LINE
CP-02	NEW LAY-IN CEILING
CP-03	B.O. NEW HEADER @ 8'-6"
CP-04	LIGHT FIXTURES TO REMAIN, CONTRACTOR TO CLEAN FIXTURES AND LENSES
CP-05	EXISTING LAY-IN CEILING
CP-06	CEILING MOUNTED PROJECTOR RE: 421/B4
CP-07	CEILING MOUNTED PROJECTOR SCREEN

CONSULTANTS

STATE OF UTAH
RALPH M. STANISLAW
95-910618-0301
LICENSED ARCHITECT

KEY PLAN

AE121

CLIENT

DIGITAL PHOTO LAB
UNIVERSITY BUILDING # 132
STATE BUILDING # 4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER



architecture • planning • design services

1135 South West Temple, Ste. A


Salt Lake City, UT 84101

P:(801) 961-7070

F:(801) 961-7373

CONSULTANTS

PROFESSIONAL SEAL



ISSUE



MARK	DATE	DESCRIPTION
DFCM CONTRACT NO:		077004
DFCM PROJECT NO:		06126730
ARCHIPLEX PROJECT NO:		0620.01
DRAWN BY:		E. RUSTEN
CHECKED BY:		R. STANISLAW
SCALE:		1/2"=1'-0"
DATE:		OCTOBER 27, 2006

KEY PLAN

SHEET TITLE

ENLARGED
FLOOR
PLAN

AE401



B4 | DESK CONFIGURATION ISOMETRIC –INFORMATION ONLY

AE401

REF.

SCALE: NTS



-INFORMATION ONLY


A1 | ENLARGED FURNITURE PLAN

AE40

REF. AE101



SCALE: 1/2" = 1'-0"





GENERAL NOTES	
1.	FIELD VERIFY ALL EXISTING CONDITIONS AND THEIR COMPATIBILITY WITH NEW CONSTRUCTION PRIOR TO THE COMMENCEMENT OF WORK. COORDINATE DISCREPANCIES WITH ARCHITECT.
2.	DO NOT SCALE DRAWINGS.
3.	SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR MORE INFORMATION.
4.	FASTEN BOARDS, SCREENS, PROJECTOR, AND OTHER CLASSROOM ACCESSORIES ACCORDING TO MANUFACTURER'S REQUIREMENTS

INTERIOR ELEVATION KEYNOTES	
(IE-01)	BACK SPLASH
(IE-02)	CORK BOARD – COORDINATE FINAL LOCATION W/ OWNER
(IE-03)	PROJECTION SCREEN RE: SPEC.
(IE-04)	WHITE MARKER BOARD – COORDINATE FINAL LOCATION W/ OWNER
(IE-05)	COMPUTER DESKS
(IE-06)	BASE AS SCHEDULED
(IE-07)	PAINT DOOR FRAME TO MATCH EXISTING
(IE-08)	PROJECTOR RE: SPEC. RE: AE421/B4
(IE-09)	EXISTING ELECTRICAL PANEL



CLIENT

SOUTHERN
UTAH
UNIVERSITY

DIGITAL PHOTO LAB
UNIVERSITY BUILDING # 132
STATE BUILDING # 4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHIPLEX
GROUP

architecture • planning • design services

1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

PROFESSIONAL SEAL

ISSUE

MARK	DATE	DESCRIPTION

MARK DATE DESCRIPTION

DFCM CONTRACT NO: 077004
DFCM PROJECT NO: 06126730
ARCHIPLEX PROJECT NO: 0620.01
DRAWN BY: E. RUSTEN
CHECKED BY: R. STANISLAW
SCALE: AS SHOWN
DATE: OCTOBER 27, 2006

KEY PLAN

SHEET TITLE

INTERIOR
ELEVATIONS
AND DETAILS


AE421

ALTERNATE # 1 WINDOW SCHEDULE																
WINDOW NUMBER	ROOM NUMBER	WINDOW						FRAMES			DETAILS			LABEL (MINUTES)	HARDWARE SET	REMARKS
		TYPE	WIDTH*	HEIGHT*	MATERIAL	FINISH	GLASS	TYPE	MATERIAL	FINISH	HEAD	JAMB	SILL			
W205A	205	A	4'-0"	4'-0"	-	-	-	EXST.	EXST.	EXST.	AE601/A1	AE601/B1	AE601/C1	-	-	REPLACE EXISTING SPANDREL WITH NEW VISION GLASS
W206A	206	A	4'-0"	4'-0"	-	-	-	EXST.	EXST.	EXST.	AE601/A1	AE601/B1	AE601/C1	-	-	REPLACE EXISTING SPANDREL WITH NEW VISION GLASS
W207A	207	A	4'-0"	4'-0"	-	-	-	EXST.	EXST.	EXST.	AE601/A1	AE601/B1	AE601/C1	-	-	REPLACE EXISTING SPANDREL WITH NEW VISION GLASS


ABBREVIATIONS
WD WOOD
HM HOLLOW METAL
* COORDINATE WINDOW SIZE WITH EXISTING WINDOW WALL SYSTEM

IG-1: GLAZING TO MATCH EXISTING IN ROOM 209.
REFER TO SPEC. FOR ADDITIONAL INFORMATION.


WINDOW AND FRAME "A"



A1 WINDOW HEAD DETAIL
AE601 REF. SCALE: 3" = 1'-0"



C1 WINDOW SILL DETAIL
AE601 REF. SCALE: 3" = 1'-0"




B1 WINDOW JAMB DETAIL
AE601 REF. SCALE: 3" = 1'-0"

ROOM FINISH SCHEDULE											
RM #	ROOM NAME	FLOOR	BASE	WALLS				DOORS			NOTES
				NORTH	SOUTH	EAST	WEST	DOOR	FRAME	CEILING	
200	RECEPTION AREA	1	1	1	1	1	1	3	2	1, 2	
201	OFFICE	1	1	1	1	1	1	1	1	1	
202	DIGITAL PHOTO LAB	1	1	1	1	1	1	3	2	1	
203	CLOSET	2	1	1	1	1	1	3	2	3	
204	SLIDE LIBRARY	1	1	1	1	1	1	3	2	1	
205	OFFICE	1	1	1	1	1	1	1	1	1	
206	OFFICE	1	1	1	1	1	1	1	1	1	
207	OFFICE	1	1	1	1	1	1	3	2	1	
208	CORRIDOR	1	1	1	1	1	1	3	2	1	
209	OFFICE	1	1	1	1	1	1	3	2	2	
210	OFFICE	1	1	1	1	1	1	3	2	2	
211	OFFICE	1	1	1	1	1	1	3	2	2	
212	STORAGE	2	2	1	1	1	1	3	2	2	

ROOM FINISH LEGEND				
FLOOR	BASE	WALLS	DOOR & FRAMES	CEILINGS
1. CARPET - CHOC. CRAVING CARPET TILE 2. SEALED CONCRETE	1. 4" CARPET COVE BASE 2. NONE	1. GYPSUM BOARD - PAINTED	1. REFINISH REUSED DOORS AND FRAMES TO MATCH 2. STEEL - PAINTED 3. WOOD	1. NEW A/C TILE AND GRID 2. EXISTING - NEW PAINT 3. OPEN TO STRUCTURE

DOOR SCHEDULE																
DOOR NUMBER	ROOM NUMBER	DOORS						FRAMES			DETAILS			HARDWARE SET	REMARKS	
		TYPE	WIDTH	HEIGHT	MATERIAL	FINISH	GLASS	TYPE	MATERIAL	FINISH	HEAD	JAMB	THRESHOLD			LABEL (MINUTES)
D201A	201	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	NEW DOOR AND FRAME TO REPLACE SMALLER EXISTING DOOR
D202A	202	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	-
D203A	203	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	-
D204A	204	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	-
D205A	205	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	RE-USE EXISTING DOOR FROM DEMOLITION
D206A	206	A	3'-0"	7'-0"	WD	STAIN	-	1	HM	PT	AE601/B5	AE601/A5	-	-	1	RE-USE EXISTING DOOR FROM DEMOLITION
D207A	207	EXST.	EXST.	EXST.	EXST.	STAIN	-	EXST.	EXST.	PT	EXST.	EXST.	-	-	-	REFINISHED EXISTING DOOR & PNT. FRAME
D209A	209	EXST.	EXST.	EXST.	EXST.	STAIN	-	EXST.	EXST.	PT	EXST.	EXST.	-	-	-	REFINISHED EXISTING DOOR & PNT. FRAME
D210A	210	EXST.	EXST.	EXST.	EXST.	STAIN	-	EXST.	EXST.	PT	EXST.	EXST.	-	-	-	REFINISHED EXISTING DOOR & PNT. FRAME
D211A	211	EXST.	EXST.	EXST.	EXST.	STAIN	-	EXST.	EXST.	PT	EXST.	EXST.	-	-	-	REFINISHED EXISTING DOOR & PNT. FRAME
D212A	212	EXST.	EXST.	EXST.	EXST.	STAIN	-	EXST.	EXST.	PT	EXST.	EXST.	-	-	-	REFINISHED EXISTING DOOR & PNT. FRAME
HARDWARE SET 1 3Ea. Hinge TAZ214 4.5 x 4.5 26D McKinney 1Ea. Wall Stop 409 32D Rockwood 1Ea. Lock Set Guard ND Schlage Vando 3Ea. Silencer SR 64/SR 65 Grey Ives																



GENERAL NOTES
1. FIELD VERIFY ALL EXISTING CONDITIONS AND THEIR COMPATIBILITY WITH NEW CONSTRUCTION PRIOR TO THE COMMENCEMENT OF WORK. COORDINATE DISCREPANCIES WITH ARCHITECT.
2. DO NOT SCALE DRAWINGS.
3. SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR MORE INFORMATION.

CLIENT

SOUTHERN UTAH UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING # 132
STATE BUILDING # 4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHIPLEX GROUP
architecture • planning • design services
1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

PROFESSIONAL SEAL

RALPH M. STANISLAW
05-0088-0001
LICENSED ARCHITECT


ISSUE

MARK DATE DESCRIPTION


DFCM CONTRACT NO: 077004
DFCM PROJECT NO: 06126730
ARCHIPLEX PROJECT NO: 0620.01
DRAWN BY: E. RUSTEN
CHECKED BY: R. STANISLAW
SCALE: AS SHOWN
DATE: OCTOBER 27, 2006

KEY PLAN

B5 DOOR HEAD DETAIL
AE601 REF. SCALE: 3" = 1'-0"




A5 DOOR JAMB DETAIL
AE601 REF. SCALE: 3" = 1'-0"




SHEET TITLE

DOOR AND WINDOW SCHEDULES AND DETAILS

AE601



MECHANICAL DEMOLITION FLOOR PLAN
SCALE: 1/4" = 1'-0"



SHEET NOTES:

- 1 EXISTING EXHAUST DUCT AND GRILLES TO BE REMOVED. TAG OUT AND ABANDON ROOF MOUNTED EXHAUST FAN.
- 2 LOW PRESSURE DUCTWORK AND GRILLES TO BE REMOVED AS SHOWN.
- 3 MEDIUM PRESSURE DUCTWORK TO REMAIN
- 4 RELOCATE EXISTING T-STAT AS SHOWN ON SHEET ME101.
- 5 EXISTING CONSTANT VOLUME BOX SHALL REMAIN.
- 6 EXISTING RETURN DUCT SHALL REMAIN.
- 7 EXISTING RELIEF AIR HOOD AND DROPS SHALL REMAIN.
- 8 EXISTING ROOF MOUNTED EXHAUST FAN AND DUCT SHALL REMAIN.
- 9 EXISTING TRANSFER AIR DUCTS SHALL REMAIN.

GENERAL NOTE:

- 1 PLANS HAVE BEEN PREPARED BASED ON AS-BUILT DRAWINGS. THIS CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITION EQUIPMENT LOCATIONS, ETC. PRIOR TO PERFORMING WORK. ANY DISCREPANCIES, MODIFICATIONS, ETC. SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO MAKING CHANGES.

CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132, STATE BUILDING
#4895, 109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER


ARCHIPLEX
GROUP
architecture • planning • design services
1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS



WHW
ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
1354 East 3300 South Suite 200
SALT LAKE CITY, UTAH 84106
(801) 466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

PROFESSIONAL SEAL



ISSUE

MARK	DATE	DESCRIPTION
------	------	-------------


DFCM CONTRACT NO:	077004
DFCM PROJECT NO:	06126730
ARCHIPLEX PROJECT NO:	0620.01
DRAWN BY:	
CHECKED BY:	
SCALE:	
DATE:	October 26, 2006

KEY PLAN


SHEET TITLE

MECHANICAL
DEMOLITION
FLOOR PLAN

MD101



MECHANICAL FLOOR PLAN
SCALE: 1/4" = 1'-0"



SHEET NOTES:

- 1 CAP EXHAUST DUCT IN PLACE. TAG AND ABANDON ROOF MOUNTED EXHAUST FAN.
- 2 EXHAUST FAN TO PLENUM. TO BE CONTROLLED BY A COOLING ONLY T-STAT.
- 3 EXISTING CONSTANT VOLUME TERMINAL BOX TO REMAIN.
- 4 RE-LOCATE EXISTING THERMOSTAT AS SHOWN.
- 5 EXISTING MEDIUM PRESSURE DUCTWORK SHALL REMAIN.
- 6 EXISTING RETURN AIR DUCT SHALL REMAIN.
- 7 EXISTING RELIEF AIR HOODS AND DUCTS SHALL REMAIN.
- 8 EXISTING ROOF MOUNTED EXHAUST FAN AND DUCT SHALL REMAIN.
- 9 EXISTING TRANSFER DUCTS SHALL REMAIN.
- 10 COORDINATE WITH G.C. TO PROVIDE PENETRATION THROUGH BLOCK WALL ABOVE CEILING. FIELD VERIFY EXACT PATH FOR NEW DUCTWORK.

GENERAL NOTES:

- 1 PLANS HAVE BEEN PREPARED BASED ON AS-BUILT DRAWINGS. THIS CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONING EQUIPMENT LOCATIONS, ETC. PRIOR TO PERFORMING WORK. ANY DISCREPANCIES, MODIFICATIONS, ETC. SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO MAKING CHANGES.
- 2 ALL NEW RECTANGULAR DUCTWORK TO HAVE 1" DUCT LINER.

CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132, STATE BUILDING
#4895, 109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHIPLEX
GROUP
architecture • planning • design services
1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS



WHW
ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
1354 East 3300 South Suite 200
SALT LAKE CITY, UTAH 84106
(801) 466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

PROFESSIONAL SEAL



ISSUE

MARK DATE DESCRIPTION

DFCM CONTRACT NO: 077004
DFCM PROJECT NO: 06126730
ARCHIPLEX PROJECT NO: 0620.01
DRAWN BY:
CHECKED BY:
SCALE:
DATE: October 26, 2006

KEY PLAN

SHEET TITLE

MECHANICAL
FLOOR PLAN

ME101



LOW PRESSURE ROUND DUCT CONSTRUCTION SCHEDULE				
DUCT DIAMETER IN INCHES	MAXIMUM 2" W.G. STATIC POSITIVE		MAXIMUM 2" W.G. STATIC NEGATIVE	
	SPIRAL SEAM GAUGE	LONGITUDINAL SEAM GAUGE	SPIRAL SEAM GAUGE	LONGITUDINAL SEAM GAUGE
3 thru 8	28	28	28	24
9 thru 14	28	26	26	24
15 thru 26	26	24	24	22
27 thru 36	24	22	22	20
37 thru 50	22	20	20	18

LOW PRESSURE ROUND
DUCT CONSTRUCTION DETAIL

C2

SCALE: NONE



DETAIL
SCALE: NONE



ME501

EXHAUST FAN SCHEDULE

EXHAUST FAN SCHEDULE										
SYMBOL	MANUFACTURER & MODEL No.	SERVES	C.F.M.	STATIC PRESSURE IN. WG.	MAX NOISE SONES	MOTOR			OPER. WT. (LBS)	COMMENTS
						V - Ø - Hz	W	RPM		
EF 1	GREENHECK SP-B70	TELE/DATA CLOSET 103	50	.2	2.4	115-1-60	45	675	9	EXHAUST TO PLENUM. CONTROL WITH T-STAT.







REGISTER, LOUVER & GRILLE SCHEDULE

REGISTER, LOUVER & GRILLE SCHEDULE							
SYMBOL	TYPE	SERVICE	MAX CFM	NOMINAL SIZE	THROAT SIZE	CEILING TYPE	SCHEDULE NOTES
R-1	CEILING	RETURN	100	6/6	6"Ø	LAY-IN	1,2,3
R-2	CEILING	RETURN	185	8/8	8"Ø	LAY-IN	1,2,3
R-3	CEILING	RETURN	260	10/10	10"Ø	LAY-IN	1,2,3
R-4	CEILING	RETURN	470	14/14	12"Ø	LAY-IN	1,2,3
R-5	CEILING	RETURN	600	16/16	12"Ø	LAY-IN	1,2,3
R-6	CEILING	RETURN	850	20/20	14"Ø	LAY-IN	1,2,3

REGISTER, LOUVER AND DIFFUSER SCHEDULE NOTES:

1. MAXIMUM NC = 25 @ MAXIMUM CFM NOTED.
2. SHALL BE PRICE 535 OR EQUAL BY METALAIR, TITUS, OR KRUEGER.
3. BAKED ENAMEL FINISH WITH COLOR AS DIRECTED BY ARCHITECT.

DIFFUSER SCHEDULE

DIFFUSER SCHEDULE								
SYMBOL	TYPE	MAX CFM	FACE SIZE	NCK SIZE	CEILING TYPE	BLOW	PATTERN	SCHEDULE NOTES
	CEILING	110	6X6	6"Ø	LAY-IN	4--WAY		1,2,3,4
	CEILING	200	9X9	8"Ø	LAY-IN	4--WAY		1,2,3,4
	CEILING	380	12X12	10"Ø	LAY-IN	4--WAY		1,2,3,4

1. PROVIDE LAY-IN CEILING AND BORDER / MODULE AS REQUIRED. SEE ARCHITECTURAL CEILING PLANS.
2. MAXIMUM NC 25 AT CFM LISTED.
3. TRANSITION AS REQUIRED TO DUCT WORK SHOWN ON PLAN.
4. PRICE SMD OR EQUAL BY TITUS, METALAIRE, OR KRUEGER.

CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
RSITY BUILDING #132, STATE BUILDING
#4895, 109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHI PLEX
GROUP

architecture • planning • design services


1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS



WHW
ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
1354 East 3300 South Suite 200
SALT LAKE CITY, UTAH 84106
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

PROFESSIONAL SEAL



ISSUE

MARK	DATE	DESCRIPTION
------	------	-------------

DFCM CONTRACT NO: 077004

DFCM PROJECT NO:	06126730
------------------	----------

ARCHIPLEX PROJECT NO: 0620.01

DRAWN BY: _____

CHECKED BY: _____

SCALE: _____

DATE: October 26, 2006

KEY PLAN

SHEET TITLE

MECHANICAL SCHEDULES

ME601

EQUIPMENT SCHEDULE

NOTES:	
1. NON-FUSED DISCONNECT SWITCH	A. FURNISHED, INSTALLED, AND CONNECTED UNDER DIVISION 16
2. FUSED DISCONNECT SWITCH	B. FURNISHED AND INSTALLED UNDER ANOTHER DIVISION REQUIRING CONNECTION UNDER DIVISION 16
3. BREAKER IN ENCLOSURE	C. FURNISHED UNDER ANOTHER DIVISION BUT INSTALLED AND CONNECTED UNDER DIVISION 16.
4. MANUAL STARTER W/THERMAL OVERLOAD	D. FURNISHED, INSTALLED AND CONNECTED UNDER ANOTHER DIVISION.
5. MAGNETIC STARTER	
6. MAGNETIC STARTER/NON-FUSED DISCONNECT COMBINATION	
7. MAGNETIC STARTER/FUSED DISCONNECT COMBINATION	OVER CURRENT PROTECTIVE DEVICES
8. MAGNETIC STARTER/BREAKER COMBINATION	
9. VARIABLE FREQUENCY DRIVE	CB = CIRCUIT BREAKER - THERMAL MAGNETIC
10. REDUCED VOLTAGE STARTER	FN = FUSE - NON INDUCTIVE LOAD
11. DIRECT CONNECTION	FI = FUSE - INDUCTIVE LOAD
12. RECEPTACLE/SPECIAL PURPOSE OUTLET/ETC.	MO = MAGNETIC ONLY CIRCUIT BREAKER
13. TWO-SPEED STARTER, COORDINATE W/MOTOR TYPE	

FIXTURE SCHEDULE

TYPE	DESCRIPTION	CATALOG NUMBER	VOLTS	LAMPS
A	2X4 LAY IN TROFFER WITH ACRYLIC PRISMATIC LENS	COLUMBIA: ST824-332G-FSA12.125-3EB8LHUNV	UNV	(3) F032/835
A1	2X2 LAY IN TROFFER WITH ACRYLIC PRISMATIC LENS	COLUMBIA: ST828-217G-FSA12.125-EB8LHUNV	UNV	(2) F017/835
B	2X4 LAY-IN PARABOLIC WITH MATTE ALUM LOUVERS (DUAL LEVEL)	COLUMBIA: P4D24-332G-MA36-S-EB8LHUNV	UNV	(3) F032/835
C	2 FOOT SURFACE MOUNTED WRAPAROUND WITH ACRYLIC PRISMATIC LENS	COLUMBIA: WC2-217-EB8LHUNV	UNV	(2) F017/835
X1	CAST ALUMINUM LED EXIT SIGN WITH GREEN LETTERS AND BLACK HOUSING (AC ONLY)	DUAL LIFE: SESGBN	UNV	INCLUDED

DEMOLITION NOTES

1. COORDINATE ALL NEW ELECTRICAL EQUIPMENT REQUIREMENTS AND MAKE CONNECTION TO EXISTING SYSTEMS. THIS INCLUDES LIGHTING, POWER, SIGNAL, RACEWAY AND OTHER SYSTEMS INCLUDED UNDER DIVISION 16.
2. RELOCATE, REWIRE AND/OR RECONNECT EXISTING ELECTRICAL DEVICES AND/OR EQUIPMENT THAT FOR ANY REASON OBSTRUCTS CONSTRUCTION.
3. CONCEAL ALL RACEWAY AND WIRING IN EXISTING WALLS, CEILINGS, FLOORS, ETC. EXCEPT WHERE THE USE OF SURFACE METAL RACEWAYS (E.G. WIRE MOLD) IS INDICATED ON DRAWINGS OR IN SPEC.
4. EXISTING RACEWAYS MAY BE REUSED (IN PLACE) WHERE POSSIBLE, AND WHERE IN COMPLIANCE WITH THE SPECIFICATIONS AND THE INTENT OF THE CONTRACT DOCUMENTS. INSURE INTEGRITY OF EXISTING RACEWAY BEFORE REUSE.
5. REMOVE ALL RACEWAYS, CONDUCTORS, BOXES, DEVICES, EQUIPMENT, ETC. THAT ARE NOT TO BE REUSED.
6. REMOVE EXISTING LIGHT FIXTURES, PLACE IN CARTON, LABEL APPROPRIATELY, AND RETURN TO OWNER, OR PROPERLY DISPOSE OF FIXTURES THAT THE OWNER CHOOSES NOT TO KEEP.























DO NOT PENETRATE STRUCTURAL ELEMENTS OF FLOORS, WALLS, CEILINGS, ROOFS, ETC.
7. DISCONNECT AND RECONNECT ANY/ALL FIXTURES, DEVICES, EQUIPMENT, ETC. REQUIRED FOR PROPER COMPLETION OF THE WORK.

GENERAL NOTES

1. CONSULT ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF ALL LIGHTING FIXTURES.
2. VERIFY ALL EQUIPMENT DIMENSIONS AND LOCATIONS BEFORE BEGINNING ROUGH IN. CONSULT ALL APPLICABLE CONTRACT DRAWINGS AND SHOP DRAWINGS TO INSURE NEC CODE CLEARANCES REQUIRED AROUND ALL ELECTRICAL EQUIPMENT.
3. CONTRACTOR SHALL VERIFY ALL ELECTRICAL LOADS (VOLTAGE, PHASE, CONNECTION REQUIREMENTS, ETC.) OF EQUIPMENT FURNISHED UNDER DIVISION 15 WITH APPROVED MECHANICAL SHOP DRAWINGS BEFORE BEGINNING ROUGH IN.
4. SEE SPECIFICATIONS FOR REQUIRED COORDINATION MEETINGS WITH MECHANICAL AND CEILING CONTRACTORS.
5. SEE APPLICABLE SHOP DRAWINGS FOR ROUGH IN LOCATION OF ALL EQUIPMENT, WIRING DEVICES, ETC. WHERE APPLICABLE MOUNT ALL WIRING DEVICES ABOVE BACK SPLASH EXCEPT THOSE SERVING UNDER COUNTER EQUIPMENT.
6. SEE SPECIFICATION FOR ENERGY SAVING LAMP AND BALLAST REQUIREMENTS.
7. FINISHES OF ALL LIGHT FIXTURES SHALL BE AS SELECTED BY ARCHITECT.
8. THE ELECTRICAL CONTRACTOR SHALL NOTIFY AND COOPERATE WITH THE MECHANICAL CONTRACTOR SUCH THAT NO PIPING, DUCTS, OR EQUIPMENT FOREIGN TO THE OPERATION OF THE ELECTRICAL EQUIPMENT SHALL BE PERMITTED TO BE INSTALLED IN, ENTER OR PASS THRU ELECTRICAL ROOMS OR SPACES, OR ABOVE OR BELOW ELECTRICAL EQUIPMENT IN OTHER AREAS.
9. ELECTRICAL BOXES SHALL NOT BE LOCATED IN MASONRY COLUMNS IN BRICK WALLS OR IN GROUTED CELLS ADJACENT TO OPENINGS. COORDINATE LOCATION OF BOXES WITH MASONRY CONTRACTOR.
10. ALL PENETRATIONS OF FIRE RATED FLOORS, WALLS, AND CEILINGS SHALL BE SEALED WITH APPROVED MATERIAL TO MAINTAIN FIRE RATING OF SURFACE PENETRATED.
11. CIRCUITS EXTENDING OVER 70' FOR 120 VOLT AND 165' FOR 277 VOLT 20 AMP CIRCUITS SHALL BE RUN WITH MINIMUM #10 CONDUCTORS.

ELECTRICAL SYMBOL SCHEDULE

1. SEE FIXTURE SCHEDULE FOR TYPE, MOUNTING AND WATTAGE.
2. HEIGHT MEASURED TO TOP LINE OF THE BOX FROM THE FINISH FLOOR.
3. REFER TO DRAWINGS FOR DIRECTIONS TO THE FIXTURES.
4. DESCRIBE LIGHT SWITCH TO DIRECTLY CONTROLLED.
5. NEMA TYPE 'ND' NOT-FUSED UNLESS NOTED 'F' (FUSED). USE 'HD' 480 V.
6. HEIGHT TO BE THE LOWER OF EITHER 80" OR 6" BELOW CEILING.
7. DOUBLE ARROWS DENOTE A DOUBLE FLANGE REQUIRED.
8. DOUBLE ARROWS DENOTE A DOUBLE FLANGE UNIT.
9. COORDINATE WITH MILLWORK SHOP DRAWINGS AND ELEVATIONS FOR HEIGHT.
10. HEIGHT MEASURED TO TOP LINE OF THE BOX FROM FINISH FLOOR.
11. HEIGHT MEASURED TO BOTTOM OF THE BOX FROM FINISH FLOOR.

STANDARD MOUNTING HEIGHT UNLESS OTHERWISE NOTED ON PLANS			
SYMBOL	DESCRIPTION	MOUNTING HEIGHT	NOTES
	ONE CIRCUIT, TWO WIRE HOME RUN TO PANEL		
	2 CIRCUIT, 3 WIRE, COMMON NEUTRAL HOME RUN		
	3 CIRCUIT, 4 WIRE, COMMON NEUTRAL HOME RUN		
	CONDUIT RUN CONCEALED IN WALL OR CEILING		
	CONDUIT RUN CONCEALED IN FLOOR OR GROUND		
	CONDUIT UP		
	CONDUIT DOWN		
	CONDUIT STUB LOCATION	CAP CONDUIT	
	CEILING LIGHT FIXTURE	CEILING	1.
	WALL LIGHT FIXTURE	AS NOTED	1.
	FLUORESCENT LIGHT FIXTURE	AS NOTED	1
	FLUORESCENT EGRESS LIGHT FIXTURE	AS NOTED	UNSWITCHED
	CEILING MOUNTED EXIT LIGHT	CEILING	1,3,8.
	WALL MOUNTED EXIT LIGHT	AS NOTED	1,3,8.
	SINGLE POLE SWITCH	+4'-0"	2.
	SINGLE POLE SWITCH	+4'-0"	4. 2.
	THREE-WAY SWITCH	+4'-0"	2.
	FOUR-WAY SWITCH	+4'-0"	2.
	DUPLEX RECEPTACLE	+16" OR AS NOTED	9. 11.
	DUPLEX RECEPTACLE		9.
	ELECTRIC WATER COOLER RECEPTACLE		SEE DIAGRAM
	GROUND FAULT INTERRUPTER DUPLEX RECEPTACLE	+16" OR AS NOTED	9. 11.
	FOURPLEX RECEPTACLE	+16" OR AS NOTED	9. 11.
	PLUGMOLD	+46" OR AS NOTED	
	DATA OUTLET	+16" OR AS NOTED	9. 11.
	TELEPHONE OUTLET	+16" OR AS NOTED	9. 11.
	TELEPHONE/DATA OUTLET	+16" OR AS NOTED	9. 11.
	JUNCTION BOX ("F" IN FLOOR)	AS NOTED	
	MOTOR OUTLET	TO SUIT EQUIP.	
	MANUAL STARTER THERMAL OVERLOAD SWITCH WITH PILOT LIGHT	+4'-0"	2.
	PANEL BOARD	TOP AT +6'-0"	
	MAIN DISTRIBUTION PANEL		
	TELEPHONE TERMINAL BOARD		
	SMOKE DETECTOR	CEILING	
	ARCHITECTURAL ROOM NUMBER		
	LIGHT FIXTURE (LETTER DESIGNATES TYPE)		
	EQUIPMENT NUMBER		
	FIRE ALARM SIGNAL HORN/STROBE	+6'-8"	6.
	HEAT DETECTOR	CEILING	

INDEX OF ELECTRICAL DRAWINGS

EG101	SYMBOLS, NOTES AND SCHEDULES
EG102	ELECTRICAL SPECIFICATIONS
EE101	ELECTRICAL DEMOLITION PLAN
EL101	NEW LIGHTING PLAN
EP101	NEW POWER PLAN
EX101	ELECTRICAL DIAGRAMS

By: skyler, Oct 30, 2006 - 3:45pm
S:\2006\266a\DRAW\2610102.dwg

1

GENERAL PROVISIONS

A. REFERENCE

1. THE GENERAL CONDITIONS AND OTHER CONTRACT DRAWINGS AS SET FORTH IN THE FOREGOING PAGES ARE HEREBY INCORPORATED INTO AND BECOME A PART OF THE SPECIFICATIONS FOR WORK UNDER THIS TITLE, INsofar AS THEY APPLY HERETO.

2. ALL SPECIFICATIONS UNDER THIS DIVISION TITLE ARE DIRECTED TO AND ARE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR. UNLESS OTHER TRADES OR PERSONS ARE SPECIFICALLY MENTIONED, "ELECTRICAL CONTRACTOR" IS INFERRED AND INTENDED.

B. CONTRACT DRAWINGS

1. THE DRAWINGS ACCOMPANYING THESE SPECIFICATIONS ARE COMPLEMENTARY EACH TO THE OTHER AND WHAT IS CALLED FOR BY ONE SHALL BE AS IF CALLED FOR BY BOTH.

2. CONSULT ALL CONTRACT DRAWINGS WHICH MAY AFFECT THE LOCATION OF EQUIPMENT, CONDUIT AND WIRING AND MAKE MINOR ADJUSTMENTS IN LOCATION TO SECURE COORDINATION.

3. WIRING LAYOUT IS SCHEMATIC AND EXACT LOCATIONS SHALL BE DETERMINED BY FIELD CONDITIONS.

4. OTHER THAN MINOR ADJUSTMENTS SHALL BE SUBMITTED TO THE OWNER'S REPRESENTATIVE FOR APPROVAL BEFORE PROCEEDING WITH THE WORK.

C. JOB-SITE COPY OF DOCUMENTS

1. MAINTAIN AT THE SITE, ONE COPY OF ALL DRAWINGS, SPECIFICATIONS, ADDENDA, APPROVED SHOP DRAWINGS, CHANGE ORDERS AND OTHER MODIFICATIONS, IN GOOD ORDER AND MARKED TO RECORD ALL CHANGES MADE DURING CONSTRUCTION. THESE SHALL BE AVAILABLE TO THE OWNER'S REPRESENTATIVE. THE DRAWINGS MARKED TO RECORD ALL CHANGES MADE DURING CONSTRUCTION SHALL BE DELIVERED TO THE OWNER'S REPRESENTATIVE FOR THE OWNER UPON COMPLETION OF THE WORK. AN ADDITIONAL SET OF DRAWINGS WILL BE FURNISHED BY THE OWNER'S REPRESENTATIVE FOR THIS PURPOSE UPON REQUEST.

D. MANUFACTURER'S DRAWINGS

1. THE CONTRACTOR SHALL SUBMIT TO THE ARCHITECT FOR REVIEW, (6) COPIES OF MANUFACTURER'S DRAWINGS AND WIRING DIAGRAMS. THE ENGINEER WILL REVIEW CONTRACTOR'S SHOP DRAWINGS AND RELATED SUBMITTALS (AS INDICATED BELOW) WITH RESPECT TO THE ABILITY OF THE DETAILED WORK, WHEN COMPLETE, TO BE A PROPERLY FUNCTIONING INTEGRAL ELEMENT OF THE OVERALL SYSTEM DESIGNED BY THE ENGINEER. BEFORE SUBMITTING A SHOP DRAWING OR ANY RELATED MATERIAL TO THE ENGINEER, CONTRACTOR SHALL: REVIEW EACH SUCH SUBMISSION FOR CONFORMANCE WITH THE MEANS, METHODS, TECHNIQUES, SEQUENCES, AND OPERATIONS OF CONSTRUCTION, AND SAFETY PRECAUTIONS AND PROGRAMS INCIDENTAL THERETO, ALL OF WHICH ARE THE SOLE RESPONSIBILITY OF CONTRACTOR; APPROVE EACH SUCH SUBMISSION BEFORE SUBMITTING IT; AND SO STAMP EACH SUCH SUBMISSION BEFORE SUBMITTING IT. THE ENGINEER SHALL ASSUME THAT NO SHOP DRAWING OR RELATED SUBMITTAL COMPRISES A VARIATION UNLESS CONTRACTOR ADVISES ENGINEER OTHERWISE VIA A WRITTEN INSTRUMENT WHICH IS ACKNOWLEDGED BY ENGINEER IN WRITING. THE ITEMS, TYPES OF SUBMITTALS AND RELATED MATERIAL (IF ANY) CALLED FOR ARE INDICATED BELOW:

ITEMS	TYPE SUBMITTALS REQUIRED
LIGHTING AND POWER PANELS	SHOP DRAWINGS
LIGHTING FIXTURES	CATALOG CUTS
LIGHTING CONTROL EQUIPMENT	CATALOG CUTS
EMERGENCY LIGHTING EQUIPMENT	CATALOG CUTS

E. GUARANTEES

1. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL DEFECTS, REPAIRS AND REPLACEMENTS IN MATERIALS AND WORKMANSHIP FOR A PERIOD OF ONE (1) YEAR AFTER DATE OF SUBSTANTIAL COMPLETION AS DETERMINED BY THE OWNER'S REPRESENTATIVE. PRODUCT GUARANTEES GREATER THAN ONE (1) YEAR SHALL BE PASSED ALONG TO THE OWNER FOR FULL BENEFIT OF THE MANUFACTURER'S WARRANTY.

WORK INCLUDED

A. INSTALLATION, MATERIALS, AND WORKMANSHIP

1. FURNISH AND INSTALL ALL NECESSARY ANCHORS, SUPPORTS, STRAPS, BOXES, FITTINGS AND OTHER SIMILAR APPURTENANCES NOT INDICATED ON THE DRAWINGS BUT WHICH ARE REQUIRED FOR A COMPLETE AND PROPERLY INSTALLED SYSTEM CONSISTENT WITH THE ARCHITECTURAL TREATMENT OF THE BUILDING.

2. THE ELECTRICAL CONTRACTOR, INsofar AS THE WORK IS CONCERNED, SHALL AT ALL TIMES KEEP THE PREMISES IN A NEAT AND ORDERLY CONDITION, AND AT THE COMPLETION OF THE WORK, SHALL PROPERLY CLEAN UP AND CART AWAY DEBRIS AND EXCESS MATERIALS. ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE COST OF DUMPSTER & REFUSE DISPOSAL AS REQUIRED FOR ELECTRICAL WORK.

3. ALL MATERIALS SHALL BE NEW AND UNDETERIORATED AND OF A QUALITY NOT LESS THAN THE MINIMUM SPECIFIED.

B. COORDINATION OF PLANS AND SPECIFICATIONS

1. CONTACT THE OWNER'S REPRESENTATIVE IMMEDIATELY IF THERE IS ANY QUESTIONS REGARDING THE MEANING OR INTENT OF EITHER PLANS OR SPECIFICATIONS, OR UPON NOTICING ANY DISCREPANCIES OR OMISSIONS IN EITHER PLANS OR SPECIFICATIONS.

C. CUTTING AND PATCHING

1. PATCHING SHALL MATCH EXISTING SURFACES IN KIND AND FINISH AND SHALL BE DONE BY THE GENERAL CONTRACTOR AT THE ELECTRICAL CONTRACTOR'S EXPENSE.

2. REPAIR OF DAMAGES, BY THE ELECTRICAL CONTRACTOR, TO NEWLY PATCHED AND REFINISHED AREAS SHALL BE DONE BY THE GENERAL CONTRACTOR AT THE ELECTRICAL CONTRACTOR'S EXPENSE, TO MATCH EXISTING CONDITION.

3. WHERE REQUIRED TO MAINTAIN FIRE RATING, OPENINGS SHALL BE SEALED UTILIZING 3M BRAND FIRE BARRIER PENETRATION SEALING SYSTEMS. FIRE BARRIER OR FIRE STOP SYSTEMS FROM CROUSE-HINDS, THOMAS & BETTS OR DOW CORNING MAY BE USED AT CONTRACTOR'S OPTION. THIS INCLUDES HOLES LEFT DUE TO REMOVAL OF EXISTING CONDUITS, BUS DUCT, ETC. OPENINGS SHALL BE TEMPORARILY FIRE STOPPED UNTIL PERMANENT FIRE STOPPING IS DONE.

D. CLEANING AND PAINTING

1. ALL ELECTRICAL EQUIPMENT SHALL BE KEPT DRY AND CLEAN DURING THE CONSTRUCTION PERIOD. INTERIOR OF ALL ENCLOSURES SHALL BE CLEANED OF DIRT AND DEBRIS BEFORE INSTALLING TRIM OR COVERS.

2. ALL FINISHED SURFACES OF EQUIPMENT FURNISHED UNDER THIS CONTRACT SHALL BE THOROUGHLY CLEANED OF DIRT AND ALL SCRATCHED OR DAMAGED SURFACES SHALL BE TOUCHED UP WITH MATCHING MATERIALS BEFORE FINAL ACCEPTANCE OF THE WORK.

3. WHEN ALL WORK IS COMPLETED AND ALL WORK HAS BEEN SATISFACTORILY TESTED AND ACCEPTED BY THE OWNER'S REPRESENTATIVE, ALL CONDUIT AND OTHER EXPOSED SURFACES SHALL BE THOROUGHLY CLEANED.

CODES AND FEES

A. CODES:

1. ALL WORK PERFORMED UNDER THIS SPECIFICATION SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE AS PREPARED AND PUBLISHED BY THE NATIONAL FIRE PROTECTION ASSOCIATION AND ANY APPLICABLE STATE OR LOCAL CODES.

B. FEES:

1. OBTAIN AND PAY FOR ANY AND ALL PERMITS REQUIRED BY ALL LAWS AND REGULATIONS AND PUBLIC AUTHORITY HAVING SUCH JURISDICTION.

2

TESTS AND INSPECTIONS

A. OBTAIN ALL INSPECTIONS REQUIRED BY ALL LAWS, ORDINANCES, RULES, REGULATIONS OR PUBLIC AUTHORITY HAVING JURISDICTION AND OBTAIN CERTIFICATES OF SUCH INSPECTIONS AND SUBMIT SAME TO THE OWNER'S REPRESENTATIVE. PAY ALL FEES, CHARGES AND OTHER EXPENSES IN CONNECTION THEREIN. OBTAIN OCCUPANCY PERMIT AS REQUIRED BY OWNER. FINAL PAYMENT SHALL NOT BE MADE UNTIL OCCUPANCY PERMIT IS OBTAINED.

B. WORK SHALL BE UNACCEPTABLE WHEN FOUND TO BE DEFECTIVE OR CONTRARY TO THE PLANS SPECIFICATIONS, CODES SPECIFIED OR ACCEPTED STANDARDS OF GOOD WORKMANSHIP.

C. THE CONTRACTOR SHALL PROMPTLY CORRECT ALL WORK FOUND UNACCEPTABLE BY THE BY THE OWNER'S REPRESENTATIVE WHETHER OBSERVED BEFORE OR AFTER SUBSTANTIAL COMPLETION AND WHETHER OR NOT FABRICATED, INSTALLED OR COMPLETED. THE CONTRACTOR SHALL BEAR ALL COSTS OF CORRECTING SUCH UNACCEPTABLE WORK, INCLUDING COMPENSATION FOR THE OWNERS REPRESENTATIVE ADDITIONAL SERVICES MADE NECESSARY THEREBY.

CONDUIT

A. FURNISH AND INSTALL ALL CONDUITS, BOXES, FITTINGS, ETC., FOR A COMPLETE RACEWAY SYSTEM.

B. ALL WIRING SHALL BE RUN IN EMT CONDUIT OR MC WITH GROUND CONDUCTOR UNLESS OTHERWISE NOTED.

C. ALL CONDUIT SIZES STATED HEREIN OR MARKED ON THE DRAWINGS ARE MINIMUM SIZE AND SHALL BE NO LESS THAN 3/4" UNLESS OTHERWISE NOTED.

D. ALL CONDUIT SHALL BE SUBSTANTIALLY SUPPORTED BY PIPE STRAPS OR SUITABLE CLAMPS OR HANGERS ATTACHED TO THE ELEMENTS OF THE BUILDING STRUCTURE TO PROVIDE RIGID INSTALLATION; IN NO CASE SHALL CONDUIT BE ATTACHED OR SUPPORTED FROM ADJOINING PIPE OR INSTALLED IN SUCH A MANNER AS TO PREVENT THE READY REMOVAL OF OTHER PIPE FOR REPAIRS.

WIRE AND CABLE

A. ALL CONDUCTORS SHALL BE COPPER AND OF THE AWG SIZE AND TYPE SHOWN ON THE DRAWINGS. WHERE NO SIZE OR TYPE IS SHOWN, CONDUCTORS SHALL NOT BE LESS THAN #12 TYPE XHHW, THHN, OR THWN. CONDUCTORS #8 AWG AND LARGER SHALL BE STRANDED COPPER AND HAVE 600 VOLT INSULATION; BE UL LABELED AND OF AMERICAN MANUFACTURER.

B. ALL CONNECTIONS ARE TO BE USING PRESSURE TYPE TERMINALS.

C. THE FOLLOWING COLOR CODE SHALL BE USED:

	120/208 VOLT
PHASE A	BLACK
PHASE B	RED
PHASE C	BLUE
NEUTRAL	WHITE
GROUND	GREEN

D. CONDUCTORS NO. 10 AWG OR SMALLER SHALL HAVE INSULATION COLORED AS NOTED ABOVE.

E. CONDUCTORS NO. 8 AWG OR LARGER SHALL HAVE INSULATION COLORED AS NOTED ABOVE OR COLORED TAPE, MINIMUM SIZE 1/2", WRAPPED TWICE AROUND AT THE FOLLOWING POINTS:

- 1) AT EACH TERMINAL
- 2) AT EACH CONDUIT ENTRANCE
- 3) AT INTERVALS NOT MORE THAN 12 INCHES APART IN ALL BOXES, PANEL TUBS, SWITCHBOARDS, ETC.

F. ALL BRANCH CIRCUITS SHALL BE MARKED IN THE PANELBOARD GUTTERS. MARKERS SHALL INDICATE CORRESPONDING BRANCH-CIRCUIT NUMBERS.

G. EACH BRANCH CIRCUIT REQUIRING A NEUTRAL SHALL BE FURNISHED WITH A SEPARATE INDIVIDUAL NEUTRAL CONDUCTOR.

BOXES AND PLATES

A. FURNISH AND INSTALL ALL OUTLET, JUNCTION, AND PULLBOXES AS INDICATED ON THE DRAWINGS AND AS NECESSARY TO INSTALL THE REQUIRED CONDUIT AND WIRING IN A NEAT AND WORKMANLIKE MANNER.

B. PULLBOXES AND JUNCTION BOXES SHALL BE GALVANIZED AND OF THE CORRECT SIZE AND GAUGE, SIZED IN ACCORDANCE WITH CODE REQUIREMENTS AND SHALL BE U.L. LABELED. ANY JUNCTION COXES CONTAINING 3 OR MORE CONDUITS MUST BE 4-11/16" SQ BY 2-1/8" DEEP.

C. FLUSH OUTLET, JUNCTION AND PULLBOXES SHALL BE PRESSED STEEL GALVANIZED OR SHERARDIZED AND SHALL BE A MINIMUM OF 4" SQUARE BY 2-1/8" DEEP OR OCTAGONAL SIMILAR TO APPLETON #40. STEEL BOXES CAST IN CONCRETE SHALL BE DESIGNED FOR CONCRETE INSTALLATION.

D. FLUSH WALL BOXES IN TILE, MARBLE, BRICK OR OTHER FINISHED MASONRY WALLS SHALL BE STEEL CITY GW-135-C SERIES OR RACO 695 SERIES.

E. BOXES AT EXTERIOR AREAS TO BE WATERTIGHT AND DUST-TIGHT WITH GASKETED COVERS.

F. ALL BOXES FOR EXPOSED WORK IN FINISHED SPACES SHALL BE "FS" TYPE WITH THREADED HUBS WITH RIGID CONDUIT RISER (DEEP WIREMOLD BOXES).

G. SWITCH PLATES ON FLUSH AND CAST BOXES SHALL BE SIERRA NOS. S-IN, (P-1), S-2N (P-2), S-3N (P-3) ETC., AS REQUIRED, AND SHALL BE MADE OF SATIN FINISH #302 STAINLESS STEEL.

H. DUPLEX RECEPTACLE PLATES ON FLUSH AND CAST BOXES SHALL BE SIERRA NO. S-8N (P-8) SATIN FINISH #302 STAINLESS STEEL.

I. ALL BOXES SHALL BE RIGIDLY SUPPORTED FROM BUILDING STRUCTURE INDEPENDENT OF THE CONDUIT SYSTEM. BOXES CAST INTO MASONRY OR CONCRETE ARE CONSIDERED TO BE RIGIDLY SUPPORTED. IDENTIFY ALL JUNCTION BOXES, RECEPTACLE OUTLET BOXES ETC. WITH CIRCUIT #S CONTAINED WITHIN BOX.

WIRING DEVICES

A. WIRING DEVICES SHALL BE SIMILAR TO THOSE LISTED BELOW AND OF SPECIFIED AMPERAGE. OTHER SPECIAL PURPOSE DEVICES SHALL BE AS SPECIFIED ON THE DRAWINGS.

B. DUPLEX GROUNDING TYPE RECEPTACLE - 20 AMP, 125 VOLT - NEMA 5-20R

HUBBELL - 5352
ARROW HART - 5352

C. SINGLE POLE SWITCHES - 20 AMP, 120 VOLT

HUBBELL - 1221
ARROW HART - 1221

D. 3-WAY SWITCHES - 20 AMP, 120 VOLT

HUBBELL - 1223
ARROW HART - 1273

E. WEATHERPROOF RECEPTACLES - 20 AMP, 125 VOLT - NEMA 5-20R

HUBBELL - 5352 WITH 5205 COVER INTERMATIC GUARDIAN I SERIES, NEMA 3R COVER
ARROW HART - 5352 WITH 4500 COVER

F. G.F.I. RECEPTACLE - 20 AMP, 125 VOLT - NEMA 5-20R

HUBBELL - GF 5262 WITH MATCHING NYLON COVER PLATE OR WP-26 W.P. COVER

G. GROUND ALL RECEPTACLES IN ACCORDANCE WITH ARTICLE 250-146 OF NEC AND AS INDICATED IN THE GROUNDING SECTION OF THIS SPECIFICATION.

IDENTIFICATION

A. EACH PIECE OF SERVICE EQUIPMENT AND INDIVIDUAL SWITCHES, ALL DISCONNECTS, STARTERS, ALL EXHAUST FAN MANUAL STARTING SWITCHES.

B. IDENTIFICATION SHALL BE IN THE FORM OF LAMINATED PLASTIC NAMEPLATES, BLACK FACE, WITH THE LETTERS ENGRAVED INTO THE WHITE BACKGROUND, MINIMUM 1/4" HIGH. PLATES SHALL BE DRILLED ON EACH END FOR SHEET METAL SCREW ATTACHMENT. NO "Dymo" OR SIMILAR TYPE LABELS WILL BE ALLOWED.

C. PANELBOARD DIRECTORY: A TYPED CIRCUIT DIRECTORY SHALL BE PROVIDED INDICATING LOCAL AREA SERVED AND LOCATION FOR EACH BRANCH CIRCUIT.

3

GROUNDING

A. ALL FEEDERS AND BRANCH CIRCUITS OVER 100 VOLTS SHALL INCLUDE A GROUNDING CONDUCTOR SIZED IN ACCORDANCE WITH NEC TABLE 250-122, EXCEPT NOT BE SMALLER THAN #12 FOR POWER AND LIGHTING CIRCUITS AND #14 FOR CONTROL CIRCUITS. ALL GROUND CONDUCTORS SHALL BE GREEN, OR AS SPECIFIED UNDER SECTION 16120, "WIRE AND CABLE".

B. ALL GROUND CLAMPS SHALL BE PENN-UNION "GPL" TYPE OR SIMILAR BY O.Z. OR BURNDY.

C. CONDUIT FOR SOLITARY GROUND CONDUCTORS SHALL BE RIGID SCHEDULE 40PVC NON-METALLIC ELECTRICAL CONDUIT WITH U.L. LABEL. SOLITARY GROUND CONDUCTORS SHALL NOT BE PLACED THROUGH METALLIC SLEEVES OR CONDUITS AND SHALL NOT BE COMPLETELY ENCIRCLED BY METALLIC HANGERS OR SUPPORTS.

D. THE GROUND CONDUCTOR SHALL BE CONNECTED TO THE NEUTRAL IN ONLY TWO LOCATIONS - ON THE SUPPLY SIDE OF THE SERVICE DISCONNECT MEANS PER NEC-250-24 AND ON SEPARATELY DERIVED SYSTEMS PER NEC 250-30.

E. AT EACH RECEPTACLE BOX, THE GROUND CONDUCTOR SHALL ENTER AND CONNECT, WITH NORMAL WIRING CONNECTOR, TO: 1) THE GROUND PIGTAIL TO RECEPTACLE; 2) THE GROUND PIGTAIL TO BOX GROUND SCREW; AND 3) THE OUTGOING GROUND CONDUCTOR TO NEXT DEVICE, IF NOT AT END OF RUN. METAL TO METAL CONTACT BETWEEN THE DEVICE YOKE AND THE OUTLET BOX IS NOT ACCEPTABLE AS A BOND FOR EITHER SURFACE MOUNTED BOXES OR FLUSH TYPE BOXES.

F. CONDUIT SYSTEM SHALL BE ELECTRICALLY CONTINUOUS. ALL LOCK NUTS SHALL CUT THROUGH ENAMELED OR PAINTED SURFACES ON ENCLOSURES. WHERE ENCLOSURES AND NON-CURRENT CARRYING METALS ARE ISOLATED FROM THE CONDUIT SYSTEM, USE BONDING JUMPFERS WITH APPROVED CLAMPS. WHERE REDUCING UNIONS ARE USED AND WHERE CONCENTRIC OR ECCENTRIC KNOCKOUTS ARE NOT COMPLETELY REMOVED BONDING BUSHINGS SHALL BE REQUIRED.

INTERRUPTION OF SERVICE AND OWNER'S OPERATION

A. THE ELECTRICAL CONTRACTOR SHALL ORGANIZE HIS WORK SO THAT THESE ALTERATIONS AND ADDITIONS SHALL CAUSE A MINIMUM OF INTERFERENCE AND DISTURBANCE TO THE OWNER. ARRANGEMENTS SHALL BE MADE WITH THE OWNER AND SIGNED BEFORE INTERRUPTING SERVICE IN ANY AREA. A WRITTEN DETAILED METHOD OF INTERRUPTION PROCEDURE INDICATING ELAPSED TIME REQUIRED AND TIME OF INTERRUPTION SHALL BE PREPARED BY THE ELECTRICAL CONTRACTOR AND SUBMITTED TO THE OWNER FOR APPROVAL.

B. ALL INTERRUPTIONS OF SERVICE SHALL BE MADE WHEN THE LOAD IS AT A MINIMUM AND SHALL BE SCHEDULED AT THE OWNER'S CONVENIENCE. (SERVICE INTERRUPTIONS WILL BE SCHEDULED FOR OTHER THAN NORMAL DAYTIME WORKING HOURS. THE ELECTRICAL CONTRACTOR SHALL INCLUDE NECESSARY COST FOR OVERTIME LABOR IN ALL BIDS.)

C. AT NO TIME SHALL THE ELECTRICAL CONTRACTOR OR HIS EMPLOYEES NORMALLY WORKING ON THE PROJECT LEAVE THE FACILITY DURING A TIME WHEN ANY NORMALLY LIVE CIRCUITS OR FEEDERS ARE DISCONNECTED, WITHOUT PERMISSION OF THE ENGINEER.

D. ALL MATERIALS, CONNECTIONS AND EQUIPMENT FOR TEMPORARY CONTROL OR POWER WIRING TO MAINTAIN CONTINUITY OF SERVICE DURING CONSTRUCTION SHALL BE PROVIDED BY THE ELECTRICAL CONTRACTOR.

POWER AND LIGHTING PANELS

A. FURNISH AND INSTALL, AS SCHEDULED AND SHOWN ON THE DRAWINGS, POWER PANELS FOR OPERATION ON VOLTAGES INDICATED.

B. THE PANELS SHALL BE SQUARE D, TYPE NOOD, NEHB OR I-LINE OR EQUAL, WITH BRANCH BREAKERS AS SCHEDULED ON THE DRAWINGS.

C. ALL TERMINATIONS SHALL BE MARKED "75°C ONLY", "60/75°C" OR LISTED FOR USE OF 75°C INSULATED CONDUCTORS AT FULL 75°C AMPACITY.

D. ALL BUS BARS SHALL BE SILVER OR TIN PLATED COPPER.

E. CABINETS SHALL BE OF COMMERCIAL GALVANIZED SHEET STEEL, CODE GAUGE AND SIZE, SURFACE OR FLUSH MOUNTED AS CALLED FOR IN THE DRAWINGS. FLUSH PANELS SHALL BE FINISHED WITH PRIME COAT ONLY. DOORS SHALL BE FITTED WITH CHROME PLATED COMBINATION LOCK AND CATCH, AND ALL KEVED ALIKE.

F. NEUTRAL ASSEMBLY SHALL HAVE INDIVIDUAL ANTI-TURN SOLDERLESS TERMINALS, SIMILAR TO SQUARE D TYPE PK, FOR CONNECTION OF ULTIMATE NUMBER OF NEUTRAL WIRES. SHEET METAL TERMINAL STRIPS AND CONNECTIONS WILL BE REJECTED.

G. PANEL SHALL HAVE A COPPER GROUND BAR SIMILAR TO NEUTRAL BAR IN NUMBER, SIZE, AND TYPE OF ANTI-TURN SOLDERLESS LUGS. THIS GROUND BAR SHALL BE FACTORY BONDED TO THE PANEL TUB IN THE GUTTER SPACE OPPOSITE THE MAINS AND THE NEUTRAL ASSEMBLY AND SHALL HAVE THE SCREWDRIVER SLOTS FACING THE FRONT OF THE PANEL.

H. THE MAIN AND BRANCH BREAKERS SHALL BE TYPE OOB OR OOB-H RATED 10,000 A.I.C. MINIMUM, MOLDED CASE, TEMPERATURE COMPENSATED, QUICK-MAKE, QUICK-BREAK, WITH THERMAL-MAGNETIC TRIP AND PERMANENTLY BOLTED TO WORK BARS.

I. PANELS SHALL BE MOUNTED WITH TOP OF PANEL AT 6'-0" ABOVE FLOOR.

LIGHTING FIXTURES

A. CONTRACTOR SHALL FURNISH AND INSTALL LIGHTING FIXTURES AND LAMPS AS INDICATED IN FIXTURE SCHEDULE SHOWN ON DRAWINGS, AND SPECIFIED HEREIN.

B. LENS THICKNESS FOR FLUORESCENT FIXTURES SHALL BE 0.125 INCHES, MINIMUM (NOT NOMINAL) AND HAVE A MINIMUM WEIGHT OF 8.0 OUNCES PER SQUARE FOOT.

C. LAMP SOCKETS FOR BARE TUBE FLUORESCENT FIXTURES SHALL BE SPRING LOADED TURRET TYPE.

D. FLUSH FIXTURES MAY BE FURNISHED WITH PRE-WIRED FEATURE PROVIDED THEY ARE U.L. APPROVED FOR 75°C WIRING AND THE JUNCTION BOX CAPACITY IS SUFFICIENT FOR THE CIRCUIT WIRING REQUIREMENTS.

E. CLEARANCES FOR RECESSED PORTIONS OF FIXTURES FROM COMBUSTIBLE MATERIAL AND THERMAL INSULATION, SHALL BE IN ACCORDANCE WITH NEC ARTICLE 410-66.

F. ALL FLUORESCENT LAMP BALLAST SHALL BE ELECTRONIC WITH LESS THAN 20% HARMONIC DISTORTION. BALLAST SOUND LEVELS SHALL NOT EXCEED CLASS "A", AMBIENT NOISE LEVELS, HPF TYPE, WITH PARALLELING WIRING CONNECTION, BE CBM AND U.L. APPROVED. BALLAST MAY BE MANUFACTURED BY ADVANCE, TYPE MARK V; ETIA INDUSTRIES TYPE E2P; OR MAGNETEK-TRIAD, B SERIES; OR MOTOROLA TYPE MOTRN.

G. NEUTRAL ASSEMBLY SHALL HAVE INDIVIDUAL ANTI-TURN SOLDERLESS TERMINALS, SIMILAR TO SQUARE D TYPE PK, FOR CONNECTION OF ULTIMATE NUMBER OF NEUTRAL WIRES. SHEET METAL TERMINAL STRIPS AND CONNECTIONS WILL BE REJECTED.

H. PANEL SHALL HAVE A COPPER GROUND BAR SIMILAR TO NEUTRAL BAR IN NUMBER, SIZE, AND TYPE OF ANTI-TURN SOLDERLESS LUGS. THIS GROUND BAR SHALL BE FACTORY BONDED TO THE PANEL TUB IN THE GUTTER SPACE OPPOSITE THE MAINS AND THE NEUTRAL ASSEMBLY AND SHALL HAVE THE SCREWDRIVER SLOTS FACING THE FRONT OF THE PANEL.

4

5

I. ALL LAMP HOLDERS INSTALLED BY THE ELECTRICAL CONTRACTOR SHALL BE FURNISHED COMPLETE WITH NEW LAMPS OF THE SIZE INDICATING ON THE FIXTURE SCHEDULE.

J. FLUORESCENT LAMPS SHALL BE 32 WATT, T8 RAPID START LAMPS WITH A COLOR TEMPERATURE OF 3500°K AND A MINIMUM CRI OF 74. UNLESS NOTED OTHERWISE.

K. LAMP CURRENT CREST FACTOR SHALL NOT EXCEED 1.8 AND SHALL BE COMPATIBLE WITH BALLAST BEING UTILIZED.

L. ANY FIXTURES SCRATCHED, BENT, CRACKED OR IN ANY WAY DAMAGED BEFORE ACCEPTANCE BY OWNER SHALL BE REPLACED AT THIS CONTRACTOR'S EXPENSE.

M. ALL LAMPS SHALL BE IN WORKING ORDER AT THE TIME OF FINAL ACCEPTANCE OF THE WORK BY THE OWNER.

N. ALL LIGHTING FIXTURES ARE TO BE GROUNDDED ON THE INTERIOR OF THE FIXTURE HOUSING, ON CLEAN BARE METAL (FREE OF PAINT), BY USE OF A PIGTAIL AND FASTENED BY A SCREW USED FOR NO OTHER PURPOSE.

O. WHEREVER LIGHTING SYSTEMS ARE SUPPORTED AND FASTENED TO A CEILING SUSPENSION SYSTEM OF THE GRID TYPE, EACH FIXTURE SHALL HAVE A SUPPORT WIRE AT OPPOSITE CORNER OF EACH RECESSED FIXTURE. EACH FIXTURE SHALL BE FASTENED TO THE GRID SYSTEM IN ACCORDANCE WITH NEC ARTICLE 410-16(C) USING SUITABLE CLIPS. THE T-BAR SHALL NOT BE CUT OUT TO PROVIDE ROOM FOR THE JUNCTION BOX.

MOTOR STARTERS AND CIRCUIT DISCONNECTS

A. GENERAL: EXCEPT AS OTHERWISE INDICATED, PROVIDE MOTOR STARTERS, DISCONNECT SWITCHES, WHICH COMPLY WITH MANUFACTURER'S STANDARD MATERIALS, DESIGN AND CONSTRUCTION IN ACCORDANCE WITH PUBLISHED INFORMATION AND AS REQUIRED FOR COMPLETE INSTALLATIONS.

B. HEAVY DUTY SWITCHES: PROVIDE HEAVY-DUTY TYPE, SHEET-STEEL ENCLOSED SWITCHES, FUSIBLE OR NON-FUSIBLE AS INDICATED OF TYPES, SIZES AN ELECTRICAL CHARACTERISTICS INDICATED: RATED 240 OR 480 VOLTS, 60 HERTZ; INCORPORATING SPRING ASSISTED, QUICK-MAKE, QUICK-BREAK MECHANISMS. PROVIDE SINGLE PHASE OR THREE PHASE AND WITH SOLID NEUTRAL AS REQUIRED BY APPLICATION. EQUIP WITH OPERATING HANDLE WHICH IS CAPABLE OF BEING PADLOCKED IN "OFF" POSITION. PROVIDE NEMA 1 OR NEMA 3R AS REQUIRED BY APPLICATION, UNLESS NOTED. PROVIDE FUSIBLE SWITCHES WITH CLASS R REJECTION FUSE CLIP KITS.

C. THERMAL OVERLOAD UNITS: PROVIDE THERMAL OVERLOAD UNITS, SIZED TO ACTUAL RUNNING FULL LOAD CURRENT, NOT EXCEED FULL CURRENT, SIZE HEATERS FOR MECHANICAL EQUIPMENT AFTER AIR AND WATER BALANCING HAVE BEEN COMPLETED.

D. AC FRACTIONAL HP MANUAL STARTERS (EQUAL TO SQUARE D CLASS 2510): PROVIDE MANUAL, SINGLE-PHASE, 1 AND 2 POLE, 300 VOLT AC MAX, FRACTIONAL HP MOTOR STARTERS, OF TYPES, RATINGS AND ELECTRICAL CHARACTERISTICS INDICATED; EQUIP WITH ONE PIECE THERMAL OVERLOAD RELAY WITH FIELD ADJUSTMENT CAPACITY OF PLUS OR MINUS 10 PERCENT OF NOMINAL OVERLOAD HEATER RATING; FOR PROTECTION OF AC MOTORS OF 1 HP AND LESS. (FOR MANUALLY SPECIFIED HEREIN). PROVIDE STARTER WITH QUICK-MAKE, QUICK-BREAK TRIP FREE TOGGLE MECHANISMS, GREEN PILOT LIGHTS, AND WITH LOCK-OFF TOGGLE OPERATED HANDLE. MOUNT SURFACE UNITS IN NEMA 1 ENCLOSURES, UNLESS NOTED OTHERWISE. PROVIDE NEMA 3R ENCLOSURE IN EXTERIOR OR DAMP LOCATION UNLESS NOTED OTHERWISE. PROVIDE FLUSH MOUNTED UNITS WITH COVERPLATE TO MATCH WIRING DEVICE COVERPLATES.

E. AC LINE VOLTAGE MANUAL STARTERS (EQUAL TO SQUARE D CLASS 2510): PROVIDE LINE VOLTAGE MANUAL STARTERS, OF TYPES, RATINGS AND ELECTRICAL CHARACTERISTICS INDICATED; 2 OR 3 POLE, 600 VOLT AC MAX; EQUIP WITH PUSHBUTTON OPERATOR, LOW VOLTAGE PROTECTION FEATURE, AND GREEN PILOT LIGHT. PROVIDE STARTERS WITH TRIP FREE MECHANISM SUCH THAT CONTACTS WILL TRIP UNDER LOAD AND REMAIN OPEN UNTIL THERMAL ELEMENT HAS COOLED, AND UNIT IS RESET. MOUNT SURFACE UNITS IN NEMA 1 ENCLOSURE, UNLESS NOTED OTHERWISE. PROVIDE NEMA 3R ENCLOSURE IN EXTERIOR OR DAMP LOCATION, UNLESS NOTED OTHERWISE. PROVIDE OVERLAPPING TRIM FOR FLUSH MOUNTED UNITS.

F. AC COMBINATION NON-REVERSING MAGNETIC STARTERS (EQUAL TO SQUARE D CLASS 8538) : PROVIDE LINE VOLTAGE COMBINATION STARTERS, OF TYPES, RATINGS, AND ELECTRICAL CHARACTERISTICS; 2 OR 3 POLE, 600 VOLT MAXIMUM WITH NON-REVERSING MAGNETIC STARTERS AS SPECIFIED HEREIN: IN COMMON CUBICLE OR ENCLOSURE WITH FUSIBLE DISCONNECT SWITCH. PROVIDE QUICK-MAKE, QUICK-BREAK, DISCONNECT FOR NEMA SIZES 1, 2, 3, AND 4; AND VISIBLE BLADE, AUTOMATIC CIRCUIT INTERRUPTERS WITH PUSH-TO-TRIP FEATURE AND SEPARATE FUSE CLIPS FOR LARGER NEMA SIZES. FUSE ALL STARTERS WITH DUAL-ELEMENT (TIME-DELAY) FUSES EQUAL TO BUSSMAN FRN/FRS-R. EQUIP DISCONNECT SWITCH WITH CLASS R REJECTION FUSE KITS. PROVIDE COMBINATION STARTERS FOR INDIVIDUAL MOUNTING, OR FOR GROUP MOUNTING IN MOTOR CONTROL CENTERS AS INDICATED. PROVIDE NEMA 1 ENCLOSURES UNLESS OTHERWISE INDICATED. PROVIDE NEMA 3R ENCLOSURE IN EXTERIOR OR DAMP LOCATIONS, UNLESS NOTED OTHERWISE.

MOTOR AND EQUIPMENT WIRING

A. PROVIDE POWER AND CONNECT ALL MOTORS AND MOTOR DRIVEN EQUIPMENT SHOWN ON THE PLANS.

B. FURNISH, INSTALL AND CONNECT ALL OVER CURRENT AND DISCONNECT MEANS AS REQUIRED BY THE NATIONAL ELECTRICAL CODE.

C. MOTORS AND MOTOR DRIVEN EQUIPMENT SHALL BE FURNISHED AND INSTALLED BY OTHERS. MOTOR STARTERS, CONTROLLERS AND CONTROL DEVICES SHALL BE FURNISHED AND INSTALLED BY THE ELECTRICAL CONTRACTOR EXCEPT AS OTHERWISE NOTED. THE ELECTRICAL CONTRACTOR EXCEPT AS OTHERWISE NOTED.

D. INSTALL AND WIRE ALL MOTOR EQUIPMENT PER WIRING DIAGRAMS AND INSTRUCTIONS FURNISHED TO HIM, INCLUDING INTERLOCK WIRING BETWEEN EQUIPMENT.

COMMUNICATIONS CONDUIT SYSTEM

A. FURNISH AND INSTALL COMPLETE COMMUNICATIONS CONDUIT SYSTEM, INCLUDING RISER, COMMUNICATIONS CABINETS, JUNCTION BOXES AND COMMUNICATIONS OUTLETS AS REQUIRED.

B. CONDUIT FOR COMMUNICATIONS WALL OUTLET SHALL BE MINIMUM OF 1" UNLESS SHOWN OTHERWISE.

C. COMMUNICATIONS OUTLET BOXES SHALL BE MINIMUM OF 4" SQUARE AND PLATES SHALL MATCH RECEPTACLE PLATES. PROVIDE FLOOR OUTLET WHERE SHOWN ON THE PLANS.

D. BENDS IN CONDUITS SHALL BE LONG SWEEP BENDS.

E. NO WIRING SHALL BE INCLUDED IN THE COMMUNICATIONS CONDUIT SYSTEM, EXCEPT #14 NYLON PULL CORDS TO BE INSTALLED THROUGHOUT.

F. CONDUIT SYSTEM SHALL BE CONTINUOUS FROM ALL OUTLETS TO COMMUNICATIONS CABINET REAM AND BUSH CONDUITS.

CLIENT

**SOUTHERN
UTAH
UNIVERSITY**
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132
STATE BUILDING #4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720


DESIGNER

**ARCHI PLEX
GROUP**
architecture • planning • design services
1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

BNA Consulting Engineers
Electrical Engineering
& Lighting Design
1704 West Sunset Blvd., Suite #4
Salt Lake City, UT 84119
Tel (435)628-3670 Fax (435)628-3680
© 2005 BNA Consulting Engineers

PROFESSIONAL SEAL



ISSUE

MARK	DATE	DESCRIPTION
------	------	-------------

DFCM CONTRACT NO: 077005
DFCM PROJECT NO: 06128730
BNA PROJECT NO: 06266SG.01

DRAWN BY:
CHECKED BY:
SCALE: AS NOTED
DATE: OCTOBER 27, 2006

KEY PLAN



SHEET TITLE

**ELECTRICAL
SPECIFICATIONS**

EG102

D
C
B
A

By: skyler, Oct 30, 2006 - 3:45pm
S:\2006\266a\DRAW\4EE101.dwg



SHEET KEYNOTES

- EXISTING RECESSED FLANGED 1X4 TWO LAMP FLUORESCENT LIGHT FIXTURE TO BE REMOVED. DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRE BACK TO NEAREST ACCESSIBLE JUNCTION BOX AND LABEL AS SPARE.
- EXISTING RECESSED DARK ROOM LIGHT TO BE REMOVED. DISCONNECT ALL ASSOCIATED CONDUIT AND WIRE. BACK TO NEAREST ACCESSIBLE JUNCTION BOX AND LABEL AS SPARE.
- EXISTING RECESSED GRID 2X4 4 LAMP FLUORESCENT LIGHT FIXTURE TO BE REMOVED. DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRE BACK TO NEAREST ACCESSIBLE JUNCTION BOX AND LABEL AS SPARE.
- EXISTING DARK ROOM "IN USE" LIGHT FIXTURE TO BE REMOVED. DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRE BACK TO NEAREST ACCESSIBLE JUNCTION BOX AND LABEL AS SPARE.
- EXISTING TOGGLE SWITCH TO BE REMOVED DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRE.
- EXISTING DUPLEX RECEPTACLE TO BE REMOVED. DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRE BACK TO NEAREST ACCESSIBLE JUNCTION BOX AND LABEL AS SPARE. PROVIDE COVER PLATE FOR ALL UNUSED RECEPTACLE LOCATIONS IN EXISTING MASONRY WALLS WHICH ARE NOT TO BE REUSED.
- EXISTING DUPLEX RECEPTACLE TO REMAIN. MAINTAIN EXISTING CIRCUITING.
- EXISTING ISLAND RECEPTACLE FED FROM BELOW FLOOR. DISCONNECT AND REMOVE ALL ASSOCIATED CONDUIT AND WIRES AND PATCH FLOOR AS NECESSARY.
- EXISTING FIRE ALARM DEVICE TO BE DISCONNECTED REMOVED AND RELOCATED. EXTEND CONDUIT AND WIRING AS NECESSARY TO MAINTAIN FIRE ALARM INITIATING/INDICATING CIRCUITS.
- EXISTING FIRE ALARM DEVICE TO REMAIN. MAINTAIN CIRCUITING.
- EXISTING TELEPHONE/DATA OUTLET AND CONDUIT TO BE REMOVED. DATA CABLING TO BE REMOVED BY CAMPUS I.T. PERSONAL.
- EXISTING TELEPHONE/DATA BOARD TO BE RELOCATED BY DIVISION 16. TELE/DATA CABLING PATCH PANEL ETC RELOCATED BY CAMPUS I.T. PERSONAL.
- EXISTING HVAC EQUIPMENT TO REMAIN. MAINTAIN EXISTING CIRCUITING.

CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132
STATE BUILDING #4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHI PLEX
GROUP

architecture • planning • design services

1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P: (801) 961-7070
F: (801) 961-7373

CONSULTANTS

BNA Consulting Engineers
Electrical Engineering
& Lighting Design
1704 West Sunset Blvd., Suite #4
St. George, Utah 84770
Tel: (435) 628-3670 Fax: (435) 628-3680
© 2005 BNA Consulting Engineers

PROFESSIONAL SEAL



ISSUE

MARK DATE DESCRIPTION

DFCM CONTRACT NO: 077005
DFCM PROJECT NO: 06128730
BNA PROJECT NO: 06266SG.01

DRAWN BY:
CHECKED BY:
SCALE: AS NOTED
DATE: OCTOBER 27, 2006

KEY PLAN

SHEET TITLE

ELECTRICAL
DEMOLITION
PLAN

EE101


D
C
B
A

By: skyler, Oct 30, 2006 - 3:45pm
S:\2006\266a\DRAW\EL101.dwg

1 2 3 4 5

SHEET KEYNOTES

- 1
- CONNECT EMERGENCY EXIT/EGRESS LIGHT FIXTURE TO UNSWITCHED CONDUCTOR OF NEAREST EMERGENCY LIGHTING CIRCUITOR PROVIDE NEW CIRCUIT IF NEEDED.
- 2
- EXTEND 3/4" CONDUIT WITH 2 # 12 THHN CU. & 1 #12 GND. AS REQUIRED AND CONNECT INTO EXISTING LIGHTING CIRCUIT CURRENTLY FEEDING LIGHTING IN THIS AREA.
- 3
- PROVIDE DUAL LEVEL SWITCHING OF FIXTURES INDICATED. SWITCH INBOARD LAMPS AND OUTBOARD LAMPS SEPERATELY.



PLAN NORTH
NEW LIGHTING PLAN
1/4"=1'-0"
0 2' 4' 8'

CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132
STATE BUILDING #4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHI PLEX
GROUP
architecture • planning • design services
1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

BNA Consulting Engineers
Electrical Engineering
& Lighting Design
1704 West Sunset Blvd., Suite #4
St. George, Utah 84770
Tel (435)628-3670 Fax (435)628-3680
© 2005 BNA Consulting Engineers

PROFESSIONAL SEAL



ISSUE

MARK	DATE	DESCRIPTION
DFCM CONTRACT NO:	077005	
DFCM PROJECT NO:	06128730	
BNA PROJECT NO:	06266SG.01	
DRAWN BY:		
CHECKED BY:		
SCALE:	AS NOTED	
DATE:	OCTOBER 27, 2006	

KEY PLAN

SHEET TITLE


NEW LIGHTING
PLAN

EL101

1 2 3 4 5

D
C
B
A

By: skyler, Oct 30, 2006 - 3:46pm
S:\2006\266a\DRAW\6EP101.dwg



SHEET KEYNOTES

1. PROVIDE 1" CONDUIT FORM SURFACE RACEWAY TO VOICE/DATA BOARD IN CLOSET 103.
2. PROVIDE TWO COMPARTMENT SURFACE MOUNTED RACEWAY EQUAL TO WIREMOLD G5400 SERIES. PROVIDE POWER AND DATA OUTLETS AS INDICATED. REFER TO ARCHITECTURAL CABINET SECTIONS AND ELEVATIONS FOR MOUNTING HEIGHTS AND EXACT LOCATIONS.
3. NEW LOCATION OF RELOCATED VOICE/DATA BOARD, AND FOURPLEX RECEPTACLE.
4. PROVIDE CEILING JUNCTION BOX AND EXTEND 2 #12 THHN CU. & 1 #12 GND. AS REQUIRED AND CONNECT TO STARE CIRCUIT IN PANEL 'LG1'. FINAL ELECTRICAL CONNECTION TO VIDEO PROJECTION BY OTHERS.
5. TEACHER CONTROL STATION. PROVIDE JUNCTION BOX WITH (1) 1" CONDUIT TO CEILING PROJECTOR LOCATION AND (1) 1" CONDUIT TO CEILING PROJECTOR SCREEN LOCATION. PROJECTOR CONTROL STATION, SCREEN AND CONTROL WIRING PROVIDED BY OWNER.
6. PROVIDE CEILING JUNCTION BOX AND EXTEND 2 #12 THHN CU. & 1 #12 GND. AS REQUIRED AND CONNECT TO SPARE CIRCUIT IN PANEL 'LG1'. FINAL ELECTRICAL CONNECTION TO PROJECTOR SCREEN BY DIVISION 16.
7. PROVIDE NEW TYPED PANEL DIRECTORY CARD REFLECTING ALL CHANGES MADE TO CIRCUITING UNDER THIS REMODEL.
8. PROVIDE 6" ROUND 70 WATT (8 OHM) CEILING MOUNTED SPEAKER EQUAL TO ATLAS FAP82T. EXTEND 14 GA. SPEAKER WIRE TO VOLUME CONTROL JUNCTION BOX TEACHERS DESK. VOLUME CONTROL AND ADDITIONAL AUDIO EQUIPMENT PROVIDED AND INSTALLED BY OTHERS.
9. PROVIDE ADDRESSABLE FIRE ALARM DEVICES COMPATIBLE WITH EXISTING SYSTEM. EXTEND CONDUIT AND WIRING AS REQUIRED AND CONNECT INTO NEAREST ADDRESSABLE FIRE ALARM LOOP.

CLIENT

SOUTHERN
UTAH
UNIVERSITY

DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132
STATE BUILDING #4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHI
PLEX
GROUP

architecture • planning • design services

1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

BNA Consulting Engineers
Electrical Engineering
& Lighting Design
1704 West Sunset Blvd., Suite #4
St. George, Utah 84770
Tel: (435) 628-3670 Fax: (435) 628-3680

© 2005 BNA Consulting Engineers

PROFESSIONAL SEAL



ISSUE

MARK DATE DESCRIPTION

DFCM CONTRACT NO: 077005

DFCM PROJECT NO: 06128730

BNA PROJECT NO: 06266SG.01

DRAWN BY:

CHECKED BY:

SCALE: AS NOTED

DATE: OCTOBER 27, 2006

KEY PLAN








SHEET TITLE

NEW POWER
PLAN

EP102

D
C
B
A

By: skyler, Oct 30, 2006 - 3:46pm
S:\2006\266a\DRAW\7E101.dwg



CLIENT

SOUTHERN
UTAH
UNIVERSITY
DIGITAL PHOTO LAB
UNIVERSITY BUILDING #132
STATE BUILDING #4895
109 SOUTH 800 WEST
CEDAR CITY, UTAH 84720

DESIGNER

ARCHIPIX
GROUP

architecture • planning • design services

1135 South West Temple, Ste. A
Salt Lake City, UT 84101
P:(801) 961-7070
F:(801) 961-7373

CONSULTANTS

BNA Consulting Engineers
Electrical Engineering
& Lighting Design
1704 West Sunset Blvd., Suite #4
St. George, Utah 84770
Tel: (435) 628-3670 Fax: (435) 628-3680
© 2005 BNA Consulting Engineers

PROFESSIONAL SEAL

LICENSED PROFESSIONAL ENGINEER
No. 4816
GARY W. MESKER
STATE OF UTAH

ISSUE

MARK DATE DESCRIPTION

DFCM CONTRACT NO: 077005
DFCM PROJECT NO: 06128730
BNA PROJECT NO: 06266SG.01

DRAWN BY:
CHECKED BY:
SCALE: AS NOTED
DATE: OCTOBER 27, 2006

KEY PLAN

SHEET TITLE

ELECTRICAL
DIAGRAMS

EX101